

Collection Location spa	Collector and Phone rubble barney 319/555-1212	Client Reference	Accession # 378984
ANYTOWN, IA 57999	Collected 2019-01-22 10:35	Received 2019-01-22 11:34	Project
Report To	Sample Information ANYTOWN INN AND SUITES 2965 RIVERVIEW RD ANYTOWN, IA 57999		Sample Description spa water
			Sample Type Non-Drinking Water
			Sample Source
			Sample Note(s) 1

ADDITIONAL SAMPLE INFORMATION

Facility Name: ANYTOWN INN AND SUITES	pH: 7.2
Free Chlorine/Br: 3.40	Oxidation Reduction Potential: Not Provided
Total Chlorine/Br: Not Provided	Recheck: No

RESULTS OF ANALYSIS - FINAL REPORT Report Status: Final Report or Interim Report

TEST	RESULT (/100 mL)	Units	ANALYSIS NOTE(S)
Total Coliform Bacteria, SM 9223 B Total Coliform Bacteria	Absent, Bacterially Safe		2
Pseudomonas aeruginosa Bacteria, Pseudalert P/A Pseudomonas aeruginosa	Absent		3

SAMPLE AND ANALYSIS NOTES Sample and Analysis Quality Assurance (QA) Events, Notes, and Test Trailers

1. Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.
2. If the total coliform bacteria test result is "Absent, Bacterially Safe," this result is satisfactory. If the total coliform bacteria test is "Present, Bacterially Unsafe" this result is UNSATISFACTORY and may indicate a possible sanitary defect in the system. State regulations for public pools and spas require that one recheck sample be collected after a positive result. A recheck sample container has been mailed to your facility. Contact your county pool/spa inspector for information and guidance if necessary.
3. If the Pseudomonas aeruginosa bacteria test result is "Absent," this result is satisfactory. If the Pseudomonas aeruginosa bacteria test is "Present," this result is UNSATISFACTORY and may indicate a possible sanitary defect in the system. State regulations for public pools and spas require that one recheck sample be collected after a positive result. A recheck sample container has been mailed to your facility. Contact your county pool/spa inspector for information and guidance if necessary.

ANALYSIS INFORMATION

TEST	ANALYZED	SITE	RELEASED	ANALYSIS PREP
1. Total Coliform Bacteria, SM 9223 B	2019-01-22 15:20 DPH	3202	2019-01-23 14:43 MBH	
2. Pseudomonas aeruginosa Bacteria, Pseudalert P/A	2019-01-22 15:20 DPH	3202	2019-01-23 14:43 MBH	

DESCRIPTION OF UNITS

/100 mL = Number per 100 Milliliters



Collection Location	Collector	Client Reference	Accession #
spa	rubble barney		378984

SITE(S) PERFORMING TESTING

3202 STATE HYGIENIC LABORATORY LAKESIDE, LAKESIDE LABORATORY, 1838 HWY 86, MILFORD, IA 51351; Phone 712/337-3669.6; Fax 712/337-0227; Susie Yuan Dai, Ph.D., Associate Director; IOWA ENVIRONMENTAL LAB ID #393

The result(s) of this report relate only to the items analyzed. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.