



Collection Location plant tap	Collector rubble barney	Client Reference special	Accession # 378982	
PWS ID/PWS Name IA5225101 UNIVERSITY WATER SYSTEM	Collected 2019-01-21 12:45	Received 2019-01-22 11:41	Project	
Report To ANYTOWN WATER SUPPLY 2000 BALD EAGLE LN ANYTOWN, IA 50999	Sample Information		Facility ID 02	Sampling Pt ID 02
			SDWA Sample Type SP - Special	Sample Category Chemical
			Sample Type Drinking Water	
			Sample Note(s) 1	

RESULTS OF ANALYSIS - FINAL REPORT Report Status: Final Report or Interim Report

TEST	RESULT (mg/L)	Units	QUANT LIMIT	MCL	ANALYSIS NOTE(S)
Nitrate as N, EPA 300.0 Nitrate nitrogen as N	9.5	Test Results	1	10	2

SAMPLE AND ANALYSIS NOTES Sample and Analysis Quality Assurance (QA) Events, Notes, and Test Trailers

1. Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.
2. The MCL (maximum contaminant level) is only applicable to compliance monitoring samples under the Safe Drinking Water Act (SDWA).

ANALYSIS INFORMATION

TEST	ANALYZED	SITE	RELEASED	ANALYSIS PREP
1. Nitrate as N, EPA 300.0	2019-01-22 19:53 MGB	3201	2019-01-23 12:46 MBH	

DESCRIPTION OF UNITS

mg/L = Milligrams per Liter

SITE(S) PERFORMING TESTING

3201 STATE HYGIENIC LABORATORY ANKENY, IOWA LABORATORIES COMPLEX, 2220 S ANKENY BLVD, ANKENY, IA 50023; Phone 515/725-1600; Fax 515/725-1642; Susie Yuan Dai, Ph.D., Associate Director; IOWA ENVIRONMENTAL LAB ID #397

The result(s) of this report relate only to the items analyzed. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.